PROPOSED CHANGES FOR POOLS & WHIRLPOOLS

		CURRENT	PROPOSED CHANGES
POOLS	Chlorine Bromine pH	.5 ppm 1.0 ppm 7.2 - 8.0 ppm	2.0 ppm 4.0 pm 7.2 - 7.8 ppm
WHIRLPOOLS	Chlorine Bromine pH	2.0 ppm 4.0 ppm 7.2 - 8.0 ppm	3.0 ppm 6.0 ppm 7.2 - 7.8 ppm
WADING POOLS	Chlorine Bromine pH	1.0 ppm 2.0 ppm 7.2 - 8.0 ppm	3.0 ppm 6.0 ppm 7.2 - 7.8 ppm

Increasing the sanitizer levels and lowering the pH (which makes the sanitizer more effective) will reduce bacterial contamination thereby providing a greater measure of safety in protecting the health of the public.