



City of Minneapolis

Call for Bid, Addendum

Official Publication No. 7558
Bids for Target Center Stainless Steel Counter Tops

December 13th, 2011

Procurement Department
330 2nd Ave South, Room 552
Minneapolis, MN 55401

Buyer Information:
Heidi Solheid, (612) 673-2727
Heidi.Solheid@minneapolismn.gov

AN AFFIRMATIVE ACTION EMPLOYER

ADDENDUM NO. 2

“BIDS FOR TARGET CENTER STAINLESS STEEL COUNTER TOPS”

That the above named bid be amended as follows:

See attached documentation for revisions. OR See below for revisions.

THE BID OPENING DATE REMAINS THE SAME

Please consider any changes and/or corrections as part of the original bid specifications and submit your bid accordingly.

Receipt of this addendum SHOULD be acknowledged on the Bid Form.

Bids opened 10 AM, Local Time, December 15th, 2011

Purchasing Department
City of Minneapolis

Item No. 1:

Sneeze Guard Information - NSF requirement for protector shelves. In this case, the "X" dimension will be zero because the protector shelves are vertical, requiring the top of the protector shelf to finish at 60" above finished floor. With the counter tops at the Target Center finishing at 34", the protector shelves should be 26" high overall to meet code. This would include the 1.5" wipe space between the bottom of the shelf and the counter top.

See Sneeze Guard Diagram