



City of Minneapolis

Call for Bid, Addendum

Official Publication No. 7749
Bids for TC Arena Sound System Sub-Bass Upgrade

January 18th, 2013

Procurement Department
330 2nd Ave South, Room 552
Minneapolis, MN 55401

Buyer Information:
Heidi Solheid, (612) 673-2727
Heidi.Solheid@minneapolismn.gov

AN AFFIRMATIVE ACTION EMPLOYER

ADDENDUM NO. 2

“BIDS FOR TARGET CENTER ARENA SOUND SYSTEM SUB-BASS UPGRADE”

That the above named bid be amended as follows:

See below for revisions:

Due to the discovery of further information concerning rigging of the system, the four clusters will be suspended from hoists. This is a change from the information provided in Addendum No. 1.

The firms of ATM and Polar Focus have prepared packages for suspending the clusters that are available to all bidders. Use of these packages by bidders will ensure that bidders have all of the equipment necessary for suspension of the clusters per specification. These packages have been approved by licensed professional engineers. If a bidder chooses to submit an alternate plan for suspension of the clusters the plan must include written approval by an engineering firm on the proposed suspension system. In addition the rigging plan must equal or exceed the pre-approved rig plans' performance including but not limited to safety, ease of use, cluster stability and capacity for future expansion. As these alternate plans have not been pre-approved, any bidder submitting an alternate is encouraged to submit a bid with one of the pre-approved plans as well in the event their alternate plan is deemed to not be equal or exceed the performance of the preapproved plans.

THE BID OPENING HAS CHANGED

Please consider any changes and/or corrections as part of the original bid specifications and submit your bid accordingly.

Receipt of this addendum SHOULD be acknowledged on the Bid Form.

Bids opened 10:00 AM, Local Time, January 24th, 2013

Purchasing Department
City of Minneapolis