

Official Publication No. 8296

Date: 5/12/16

Procurement Division
330 2nd Ave South, Room 552
Minneapolis, MN 55401

Buyer Information:
David Schlueter / 612-673-2834
david.schlueter@minneapolismn.gov

AN AFFIRMATIVE ACTION EMPLOYER

ADDENDUM NO. 1
“BIDS FOR INSTALLATION OF TWO (2), FOUR-FOLD DOORS”

Please see attached information to update and clarify the original specifications.

Please consider any changes and/or corrections as part of the original bid specifications and submit your bid accordingly.

Receipt of this addendum SHOULD be acknowledged on the Bid Form.

Bids opened 10:00 AM, Local Time, May 24th, 2016
Finance and Property Services – Procurement Division
City of Minneapolis

New Notes about the two new Bi- Fold doors/ Pump Station # 5

Main pump room door shall have four (4), removable, ¼" tempered windows (one in each door leaf). Window opening sizes shall be approximately 24" wide x 48" high. Glass shall be in its own metal frame, and include handles for easy removal of window. Windows shall include a weather seal.

Main pump room door shall include a stationary expanded metal mesh and an aluminum bug screen within the window openings.

Screen room door shall be designed with one panel being split, to allow for the lower portion of the door section to be used as a pedestrian door. This lower door section shall be interlocked with the upper door section for normal operation (similar to detail attached).

Screen room door shall include four (4), ¼" tempered windows (one in each door section). These windows will be stationary and shall be approximately 24" wide x 12" high.

Locking bolts and all door hardware for the folding doors are to be supplied by door manufacturer.

Both doors are to be manually operated. There are No Motors on these doors.

All Electrical work (if required) will be done by City Electricians.

No galvanized metal, standard heavy duty industry plates primed and painted.

Doors may come primed and painted after installations by General contractor or his subs.

