

Official Publication No. 8329

August 3, 2016

Procurement Division
330 2nd Ave South, Room 552
Minneapolis, MN 55401

Buyer Information:
Ashley Matuke, (612) 673-3371
Ashley.Matuke@MinneapolisMN.gov

AN AFFIRMATIVE ACTION EMPLOYER

ADDENDUM NO. 1

“BIDS FOR PS7 PROGRAMMABLE LOGIC CONTROLLER”

That the above named bid be amended as follows:

See attached Question and Answer documentation.

THE BID OPENING REMAINS THE SAME

Please consider any changes and/or corrections as part of the original bid specifications and submit your bid accordingly.

Receipt of this addendum SHOULD be acknowledged on the Bid Form.

Bids opened 10:00 AM, Local Time, August 16th, 2016

Finance and Property Services – Procurement Division
City of Minneapolis

Q. Is this bid for services only?

A. Yes, this is services only. Design, Drawings, Programming, and Commissioning. Allow flexibility to address retrofiting.

Q. I have questions on the old Panelview 900. Is it touch or keypad? Is it going to fit in the existing hole?

A. The panelview is a touchscreen interface. Minneapolis Water will modify the door to fit the new panelview, if needed. A new panelview will be specified in the Design (follow SCADA standards) and be purchased separately by Minneapolis Water.