



TECHNICAL POLICY

13 – 62 Special Pipe Hangers

Original Issue: May 1994
Revised: April 2006

NFPA 13 requires hanger components that attach to the building structure to meet the specific prescriptive criteria or be designed by a Professional Engineer.

When engineered hangers are used, a copy of the engineers report is to be submitted with the plans.