



TECHNICAL POLICY

20 – 01 Emergency Power Transfer Switches for Fire Pumps

Original Issue: February 1985
Revised: April 2006

1. When fire pumps are supplied by 2 sources of power, the automatic transfer switch shall be listed for fire pump service and located in the pump room. The transfer switch shall meet all of the requirements of NFPA - 20.
2. Wiring from the emergency generator to the fire pump transfer switch shall be direct and is not to be routed through other transfer switches.