



## TECHNICAL POLICY

### 13 – 40 Dry Pendent and Dry Sidewall Sprinklers

Original Issue: July 1986  
**Revised: April 2006**

There is to be a minimum of 12 inches of pipe between the wet pipe branch lines supplying the sprinkler and the warm side of the wall or ceiling that the sprinkler penetrates.

Dry type sprinklers are to be tested or replaced every 10 years.