



## TECHNICAL POLICY

### 13 – 45 Replacement of $\frac{3}{4}$ Inch Steel Pipe

Original Issue: February 1985  
**Revised: April 2006**

When an existing sprinkler system is being altered, any  $\frac{3}{4}$  inch steel pipe shall be removed and replaced with 1 inch pipe.

This policy applies to the area or floor that is being altered. The extent of the area is to be determined by MFD.