



TECHNICAL POLICY

20 – 03 Test Header Piping Restraint

Original Issue: August 1990
Revised: April 2006

The piping from the pump to the test header must be restrained from lateral and vertical movement.

Besides the normal hangers used to support the pipe from the structure, additional bracing (similar to earthquake sway bracing) is needed at each change of direction. Locations and types of bracing are to be shown on the plans.