



NOTES:

1. ALL FOUNDATION LOCATIONS SHALL BE DETERMINED IN FIELD BY TRAFFIC DIVISION AT TIME OF CONSTRUCTION.
2. FOUNDATION TOP SHALL HAVE SQUARE EDGES AND BE FINISHED ON ALL SIDES.
3. CABINET ANCHORS ARE HILTI KWIK BOLT II WEDGE ANCHORS OR EQUAL 4 PER CABINET, 1/2" X 4 1/2" STAINLESS STEEL (#304) FULL THREADED.

1 3" FROM HIGHPOINT OF FINISHED SIDEWALK GRADE,
4" FROM HIGHPOINT OF FINISHED BOULEVARD GRADE.

2 PROVIDE PROTECTIVE BUSHINGS ON ALL CONDUITS.

NO SCALE

	MINNEAPOLIS DEPARTMENT OF PUBLIC WORKS		FOUNDATION - SIGNAL CONTROLLER CABINET TYPE "P"	STANDARD PLATE NO. TRAF-1068-R1
	DRAWN: CLK	DATE: 9/10/12		
APPROVED: DRP	DATE: 9/10/12			