




MINNEAPOLIS
DEPARTMENT OF PUBLIC WORKS

DRAWN: TDS	DATE: 1/1/12
APPROVED: RCE	DATE: 1/1/12

HYDRANT BRANCH INSTALLATION

STANDARD
PLATE
NO.
WATR-1000A-R1

- NOTES:
1. OPERATING NUT SHALL BE FURNISHED WITH L.H. (COUNTER CLOCKWISE) OPENING.
 2. HYDRANTS SHALL MEET THE REQUIREMENTS IN THE SPECIAL PROVISIONS.
 3. USE EBAA MEGALUGS OR APPROVED EQUAL FOR THRUST RESTRAINT ON ALL JOINTS OF HYDRANT BRANCH.

NOT TO SCALE