

Construction (Temporary) Heaters

The following requirements shall be met prior to putting into service any construction heating equipment.

- 1. Only licensed mechanical contractors can install construction heaters. All locating and RELOCATING of construction heaters will be ONLY DONE by the licensed permitting contractor's gasfitter**
- 2. Permits are required for construction heaters and must be renewed after 1 year.**
- 3. Unvented heaters are not allowed in the enclosed portion of the building. No fuel tanks are allowed inside the building.**
- 4. All propane tanks will be installed and placed per NFPA 58**
- 5. 25 feet of flexible hose is the maximum allowed unless pre-approved by the mechanical inspector**
- 6. Flexible hose will be installed a minimum of 3 1/2 inches off the ground, supported, and out of the way of construction traffic**
- 7. All LP hoses must pass a 25 pound (minimum) 12 hour pressure test**
- 8. 100% outdoor air will be supplied to the construction heater at all times**
- 9. An approved manual shut off valve shall be installed at each unit**

Any violation of the above will result in the unit(s) being shut off by the inspector.